



TYPE 1-P CB BASE UNIT
 SEE APPLICABLE
 STANDARD DETAILS.
 CONFORMS TO WASH.
 STATE APWA/WSDOT
 STANDARD SPECIFICATIONS
 AND STANDARD PLAN.

NOTES:

1. MAX. OUTLET PIPE DIAMETER IS 8 INCHES.
2. ALL METAL PARTS AND SURFACES MUST BE MADE OF CORROSION RESISTANT MATERIAL OR GALVANIZED.



City of Bellevue

SURFACE WATER UTILITY

TITLE

SPILL CONTROL (SC) SEPARATOR
 TYPE I

MARCH, 1996

NO SCALE

NO. D-42