



BELLEVUE FIRE DEPARTMENT
 Fire Prevention Division
 450 110th AVE NE
 Bellevue, WA 98004
 PH: 425.452.6872
 FAX: 425.452.5287
www.bellevuewa.gov

STANDPIPES
 (CLASS I)
5 YEAR
TEST REPORT

STANDPIPE _____ OF _____

WET <input type="checkbox"/>	DRY <input type="checkbox"/>
------------------------------	------------------------------

ADDRESS	TIME IN:
NAME OF FACILITY	TIME OUT:

GENERAL

	YES	NO	N/A		YES	NO	N/A
DATE OF LAST HYDROSTATIC TEST?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	PRV 's TESTED? (IF YES - LOG PRESSURES ON FORM "FD - 405A")	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
ALL VALVES EXERCISED?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	PROPER SIGNAGE PROVIDED AT FDC?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PIPING BETWEEN FDC AND CHECK VALVE HYDROSTATICALLY TESTED?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	ACCESS TO FDC IS FREE FROM OBSTRUCTIONS?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HOSE CONNECTION HAS NATIONAL STANDARD THREADS?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	ALL OUTLET VALVES & HOSE THREADS CHECKED FOR DAMAGE?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FDC CONNECTION CLAPPER VALVES FREE FROM OBSTRUCTION?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	VERIFY ALL WATERFLOW SWITCHES OPERATE? (IF PRESENT)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FLOW TEST CONDUCTED AT HYDRO-STATICALLY MOST REMOTE CONNECTION? WATERFLOW REQ'D = 300 GPM@ 150PSI. (REF. BFDDS)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	ALL FIRE DEPARTMENT INLETS & OUTLETS EQUIPPED WITH APPROVED PLUGS OR CAPS? (1/8 INCH PRESSURE RELIEF HOLE IN CAPS)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FIRE PUMP(S) START FROM ROOF FLOW?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	ALL CONTROL VALVES LEFT IN OPEN POSITION? (EXCEPT NORMALLY CLOSED VALVES)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

COMMENTS

PROBLEMS FOUND : YES <input type="checkbox"/>	NO <input type="checkbox"/>
CORRECTIONS MADE: YES <input type="checkbox"/>	NO <input type="checkbox"/>

THE WASHINGTON ADMINISTRATIVE CODE (WAC) 212-80-175 WAS MODIFIED IN 2005 TO REQUIRE ANY PERSON THAT OFFERS TO CONTRACT TO PROVIDE INSPECTION AND TESTING OF WATER BASED FIRE PROTECTION SYSTEMS TO BE STATE CERTIFIED TO A MINIMUM OF NICET INSPECTION, TESTING, AND MAINTENANCE LEVEL 2. THIS IS TO CERTIFY THAT TESTS AND INSPECTIONS CONDUCTED AND DENOTED IN THIS REPORT ARE IN ACCORDANCE WITH THE STANDARDS ADOPTED BY THE WASHINGTON STATE BUILDING CODES COUNCIL AND THE WASHINGTON STATE FIRE MARSHAL. TESTS AND INSPECTIONS REQUIRED BY THIS EVALUATION HAVE BEEN CONDUCTED IN ACCORDANCE WITH NFPA 13 AND NFPA 25.

TECHNICIAN NAME :	PRINT NAME:	SIGN :
-------------------	-------------	--------